



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA200421

Certificate Holder: Eguana Technologies Inc.
3-6143 4th Street SE
Calgary, AB T2H 2H9
Canada

Regulatory Definition: Non-Prescribed
Product Description: AC Battery System
Trade Name: Eguana Technologies
Model No.: Enduro BESS
Markings: AC Voltage Range: 183-265V AC
Frequency Range: 45-52Hz
Nominal Voltage: 240V~ 50Hz, Max 12.5A 3000VA
Off-grid: 240V~, Max 10A 2000VA
Battery: Li-ion 6.5kWh, voltage range: 42-58.8Vdc,
Max charge/discharge current: 63A
-10°C to +45°C

Standard: IEC 62109-1 Ed 1.0
IEC 62109-2 Ed 1.0
AS/NZS 4777.2:2015
AS 62040.1:2019

Conditions: Nil

Certification Mark: RCM and SAA200421

Date First Registered: 27 March 2020
Date of Expiry: 27 March 2025

R.A. Hill

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 27-03-20 200421/1

www.jas-anz.org/register